

**COMHAIRLE CONTAE FHINE GALL
FINGAL COUNTY COUNCIL**

**BALBRIGGAN/RUSH-LUSK/SWORDS AREA COMMITTEE MEETING
[SERVICES A – OPERATIONAL MATTERS]**

THURSDAY 12TH MARCH 2026

ITEM NO. 04

SURFACE WATER DRAINAGE - NAUL HILL - THE NAUL - AI107205

Question: Councillor E. Dockrell

“To ask the Chief Executive if consideration can be given for a review of the surface water drainage on Naul Hill as it is no longer fit for purpose, the drain in place (under the footpath from the school to the pedestrian crossing at the bottom of the hill) does not have the capacity to deal with the volume of water flowing into it?”

Reply:

The above location was inspected by our Storm Water Inspector and a number of issues were identified for action. The Operations Department will arrange for gullies in the road drainage at the school to be cleaned. Water is also running off land onto the road upstream of the school which is in breach of the Roads Act and enforcement action may be warranted. Similarly, a water leak at a house is feeding water onto the road surface and this will be reported to UE for follow up.

Lastly the storm water sewer from Naul Hill requires jetting and this will be included in our jetting programme.

Source of Reply: Mr J Walls, Senior Executive Engineer, Operations department.